

序号	报告编号	发布日期	结论	影像资料
8	GX-B1424/20-4-24019	2024. 12. 10	依据NB/T 10176-2019单轨吊车综合判定：合格；依据MT/T 220-1990 尾气所检项目合格。	
9	GX-B1611/23-4-24002	2024. 12. 9	所检项目合格	

10	GX-B1310/21-4-24218	2024. 12. 10	符合标准要求。 。	
11	GX-B1310/21-4-24219	2024. 12. 10	符合标准要求。	
12	GX-B1416/22-4-24018	2024/12/9	综合判定：合格。	

13	GX-B1416/22-4-24019	2024/11/29	综合判定：合格。			
14	GX-B1404/20-4-24042	2024.12.11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求			
15	GX-B1404/20-4-24043	2024.12.11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求			

16	GX-B1404/20-4-24044	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求		
17	GX-B1404/20-4-24045	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求		
18	GX-B1404/20-4-24046	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求		

19	GX-B1404/20-4-24047	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	
20	GX-B1404/20-4-24048	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	
21	GX-B1404/20-4-24049	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	

22	GX-B1404/20-4-24050	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	
23	GX-B1404/20-4-24051	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	
24	GX-B1404/20-4-24052	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求	

25	GX-B1404/20-4-24053	2024. 12. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求			
26	GX-B1310/21-4-24209	2024. 12. 4	符合标准要求			
27	GX-B1428/21-4-24209	2024. 12. 4	无缺陷痕迹显示			

28	GX-B1310/21-4-24210	2024. 12. 4	符合标准要求		 <p>2024. 11. 18</p>
29	GX-B1428/21-4-24210	2024. 12. 4	无缺陷痕迹显示		 <p>2024. 11. 18</p>















